

Administrative Order Paragraph Reference	Daily Summary Progress Report: 03/18/2025*	Result
1.e.i.	Potable Wells Sampled	331
	Total Water Sampling Events (including 1st Round, 2nd Round, and subsequent rounds, and post-treatment)	612
	Laboratory Results Received (including 1st Round, 2nd Round, and subsequent rounds, and post-treatment)	582
	Potable Wells Samples Scheduled - Total (including 1st Round, 2nd Round, and subsequent rounds, and post-treatment)	38
	Potable Wells Samples Scheduled - 1st Rd	7
	Potable Wells Samples Scheduled - 2nd or Subsequent Rounds or post-treatment	31
1.e.ii.	Total tested potable wells that exceed statewide MSCs for VOCs or presence of LNAPL (historic aggregate)	6
	LNAPL and dissolved VOC exceedences (historic aggregate)	3
	LNAPL with no VOCs (historic aggregate)	2
	Dissolved VOC exceedence only (historic aggregate)	1
	Total tested potable wells that exceed statewide MSCs for VOCs or presence of LNAPL (as of current date)	5
	LNAPL and dissolved VOC exceedences (as of current date)	3
	LNAPL with no VOCs (as of current date)	1
	Dissolved VOC exceedence only (as of current date)	1
	Total tested Potable Wells with Detections of VOCs that do not exceed Statewide MSCs for VOCs (historic aggregate)	8
	Total tested Potable Wells with Detections of VOCs that do not exceed Statewide MSCs for VOCs (as of current date)	6
	Total tested Potable Wells with Detections of VOCs below standards but above Method Detection Limit "J Value" (historic aggregate)	17
1.e.iii.	Total tested Potable Wells with Detections of VOCs that do not exceed Statewide MSCs for VOCs "J Value" (as of current date)	12
	Total Number of Properties with POET Installed	88
	POET Installed by Energy Transfer	35
	POET Installed by Others that are known to Energy Transfer	32
	POET Systems or other treatment systems for VOCs that were pre-existing	21
	Total Number POET Systems Planned	41
1.e.iv. (See detail on Tab 1.e.iv)	Total POET Systems Planned - Energy Transfer	24
	Total POET Systems Planned - Land Owners	17
	List of properties to date with operating POET or other treatment systems for VOCs	See Tab 1.e.iv
	List of properties to date with VOC detections that do not have a POET or other treatment system for VOCs (includes J value properties).	
1.e.v.	List of properties to date with planned POET	
	List of properties to date with VOC detections where Energy Transfer does not know whether the property has a POET	
1.e.v.	Properties that have requested POET and where Energy Transfer has declined to install or pay for the installation of POET	18
1.e.vi.	Properties that have requested POET but Energy Transfer has declined to install/pay; reason for declining	See Tab 1.e.vi.
1.e.vii	Tables of all property well sampling analytical results, property well gauging results, and wellhead field screening results	See Attached Tables.
1.e.viii	Site characterization activities performed	See Tab 1.e.viii.
1.e.ix	Site remediation activities performed	See Tab 1.e.ix.

*Note the information summarized herein reflects data recorded thru the previous day.

List of Properties with VOC detections that do not have POET or other treatment systems for VOCs					
1			11		21
2			12		22
3			13		23
4			14		24
5			15		25
6			16		26
7			17		27
8			18		28
9			19		29
10			20		30
List of Properties operating POET or other treatment systems for VOCs					
1		31		61	
2		32		62	
3		33		63	
4		34		64	
5		35		65	
6		36		66	
7		37		67	
8		38		68	
9		39		69	
10		40		70	
11		41		71	
12		42		72	
13		43		73	
14		44		74	
15		45		75	
16		46		76	
17		47		77	
18		48		78	
19		49		79	
20		50		80	
21		51		81	
22		52		82	
23		53		83	
24		54		84	
25		55		85	
26		56		86	
27		57		87	
28		58		88	
29		59		89	
30		60		90	
List of Properties with planned POET					
1		31		61	
2		32		62	
3		33		63	
4		34		64	
5		35		65	
6		36		66	
7		37		67	
8		38		68	
9		39		69	
10		40		70	
11		41		71	
12		42		72	
13		43		73	

14		44		74	
15		45		75	
16		46		76	
17		47		77	
18		48		78	
19		49		79	
20		50		80	
21		51		81	
22		52		82	
23		53		83	
24		54		84	
25		55		85	
26		56		86	
27		57		87	
28		58		88	
29		59		89	
30		60		90	
List of Properties with VOC detections where Energy Transfer does not know whether the property has a POET					
1		11		21	
2		12		22	
3		13		23	
4		14		24	
5		15		25	
6		16		26	
7		17		27	
8		18		28	
9		19		29	
10		20		30	

List of Properties to date that have requested POET but Energy Transfer has declined to install/pay;
reason for declining

#	Property	Reason
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		
16		

Site characterization activities performed

Date	Activity
1/20/2025	Investigated odor complaint
1/20/2025	Inspected the pipeline ROW and used a T-bar to create a hole in over 1,000 locations through which a photo ionization detection ("PID") monitor/probe was inserted to obtain a reading for the presence of volatile organic compounds ("VOCs").
1/23/2025	Collected free product samples
1/23/2025	Began potable water well sampling for laboratory analysis (approximately 30 houses)
1/23/2025	Provided bottled water to Mt. Eyre neighborhood
1/29/2025	Collected samples of free product from two (2) wells on Spencer Drive
1/29-31/2025	Performed additional static pressure tests on the pipeline.
1/30/2025	Excavated the pipeline at a location near Bruce Road and Glenwood Drive within the pipeline ROW, but did not observe any leaks at that location
1/31/2025	Excavated the pipeline along Glenwood Drive near the intersection with Walker Road and discovered the release
2/2/2025	Cut out the affected section of the pipeline and removed impacted soils from the immediate vicinity of the release location
2/3/2025	Performed a geoprobe evaluation of the area in the immediate vicinity of the release location.
2/3/2025	Performed ground penetrating radar (GPR) at eight (8) locations on Spencer Road and Glenwood Drive.
2/5/2025	Performed product recovery testing at a location along Glenwood Drive.
2/10/2025	Performed downhole geophysical analyses at one (1) location in the immediate vicinity of the release location
2/13/2025	Submitted a Notice of Intent to Remediate to begin the Act 2 process
2/18/2025	Initiated daily visual assessments of any potential impacts to surface water near investigative area
2/25/2025	Performed indoor air sampling at five (5) residences near the immediate vicinity of the release location.
2/28/2025	Performed a GPR survey along Spencer Road, as part of SPLP's efforts to locate and install product recovery wells.
3/7/2025	Completed electrical resistivity imaging (ERI), and near soil gas sampling throughout the Mt. Eyre neighborhood.
3/11/2025	Set up and shakedown for packer testing at [REDACTED]
3/12/2025	Commenced packer test at [REDACTED]
3/17/2025	Packer testing at [REDACTED]
3/17/2025	Complete packer testing at [REDACTED]
3/18/2025	Mob for recovery well drilling

Site remediation activities performed

Activity	Number	Units
Removed product entrained in soil during excavation	644	gal
Recovered free product today	1	gal
Recovered free product cumulative	74.78	gal

Tables:

Property well sampling analytical results, property well gauging results,
and wellhead field screening results

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L) 5	Toluene (µg/L) 1,000	Ethyl- benzene (µg/L) 700	Total Xylenes (µg/L) 10,000	MTBE (µg/L) 20	Isopropyl Benzene (µg/L) 840	Naph- thalene (µg/L) 100	1,2,4-Trimethyl- benzene (µg/L) 130	1,3,5-Trimethyl- benzene (µg/L) 130	1,2-Dichloro- ethane (EDC) (µg/L) 5	1,2 Dibromo- ethane (EDB) (µg/L) 0.05	Lead (µg/L) 5
DEP MSCs for a Residential, Used Aquifer																
				02/08/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0096	0.27 J
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	0.27 J
				02/15/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	2.4
				02/18/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.35 J
				02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	3.4
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	1.8
				02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.17 J
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
								0.65 J	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/05/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.82
				02/04/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	0.13 J
				03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/17/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.45 J
				03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/13/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	0.11 J	ND<0.0094	0.19 J
				02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	0.19 J	ND<0.0094	0.36 J
				02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.14 J
				03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J
				02/07/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.42 J
				02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.19 J
				03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/12/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0092	ND<0.12
				02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/10/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	ND<0.12
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.17 J
				02/11/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	ND<0.12
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/08/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L) 5	Toluene (µg/L) 1,000	Ethyl- benzene (µg/L) 700	Total Xylenes (µg/L) 10,000	MTBE (µg/L) 20	Isopropyl Benzene (µg/L) 840	Naph- thalene (µg/L) 100	1,2,4-Trimethyl- benzene (µg/L) 130	1,3,5-Trimethyl- benzene (µg/L) 130	1,2-Dichloro- ethane (EDC) (µg/L) 5	1,2 Dibromo- ethane (EDB) (µg/L) 0.05	Lead (µg/L) 5
DEP MSCs for a Residential, Used Aquifer																
				02/11/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	8.1
				02/08/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.29 J
				03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J
				02/03/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/21/2025	0.52	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	0.31 J	0.46 J	ND<0.10	ND<0.0094	ND<0.12
				02/28/2025	0.18 J	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/10/2025	0.42 J	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	0.41 J	0.30 J	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	ND<0.12
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	ND<0.12
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				09/28/2023	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	-	-	-
				01/28/2025	0.92	6.6	ND<0.50	100	ND<0.50	1.0	84	47	23	ND<0.50	ND<0.0094	0.017 J
				02/19/2025	0.13 J	0.27 J	0.72	29	ND<0.10	1.7	47	2.1	1.3	ND<0.10	ND<0.0094	ND<0.12
				02/24/2025	ND<0.10	ND<0.10	0.44 J	13	ND<0.10	0.94	30	0.32 J	0.22 J	ND<0.10	ND<0.0094	0.13 J
				02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.50	ND<0.0095	ND<0.12
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.50	ND<0.0093	ND<0.12
				02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.50	ND<0.0095	ND<0.12
				09/28/2023	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	-	-	-
				01/30/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				02/11/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	ND<0.12
				02/24/2025	0.63	ND<0.10	ND<0.10	0.63	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				01/28/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	ND<0.12
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	0.47 J
				01/28/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	0.15 J
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.15 J
				01/23/2025	12	ND<0.50	ND<0.50	0.29	ND<0.50	ND<0.50	1.3	ND<0.50	ND<0.50	ND<0.50	ND<0.0091	ND<0.12
				01/30/2025	12	ND<0.50	ND<0.50	0.19	ND<0.50	ND<0.50	1.3	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.25 J
				02/12/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				02/25/2025	14	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	2.0	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				01/29/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	ND<0.12
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L) 5	Toluene (µg/L) 1,000	Ethyl- benzene (µg/L) 700	Total Xylenes (µg/L) 10,000	MTBE (µg/L) 20	Isopropyl Benzene (µg/L) 840	Naph- thalene (µg/L) 100	1,2,4-Trimethyl- benzene (µg/L) 130	1,3,5-Trimethyl- benzene (µg/L) 130	1,2-Dichloro- ethane (EDC) (µg/L) 5	1,2 Dibromo- ethane (EDB) (µg/L) 0.05	Lead (µg/L) 5
DEP MSCs for a Residential, Used Aquifer																
				01/23/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0092	ND<0.12
				03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				01/28/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0092	0.16 J
				02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J
				03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				01/23/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0091	0.19 J
				02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				01/23/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0092	ND<0.12
				02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				01/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.63
				02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.36 J
				03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				01/31/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	0.23 J
				03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.2
				02/03/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	ND<0.12
				02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	ND<0.12
				03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J
				02/04/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	1.5
				03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.3
				03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L) 5	Toluene (µg/L) 1,000	Ethyl- benzene (µg/L) 700	Total Xylenes (µg/L) 10,000	MTBE (µg/L) 20	Isopropyl Benzene (µg/L) 840	Naph- thalene (µg/L) 100	1,2,4-Trimethyl- benzene (µg/L) 130	1,3,5-Trimethyl- benzene (µg/L) 130	1,2-Dichloro- ethane (EDC) (µg/L) 5	1,2 Dibromo- ethane (EDB) (µg/L) 0.05	Lead (µg/L) 5
DEP MSCs for a Residential, Used Aquifer																
				02/07/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.28 J
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.36 J
				02/13/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	0.93
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	5.3
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.42 J
				02/15/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				01/31/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	0.41 J
				03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/04/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.46 J
				02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.30 J
				01/28/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.16 J	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.13 J
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.22 J	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	0.14 J
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				01/29/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	0.59
				02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	1.6
				03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	0.31 J	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				01/24/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	0.12	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	ND<0.12
				02/06/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.15 J
				02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				01/24/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	1.7
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.12 J	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.50	ND<0.0093	3.1
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.50	ND<0.0093	0.13 J
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl- benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naph- thalene (µg/L)	1,2,4-Trimethyl- benzene (µg/L)	1,3,5-Trimethyl- benzene (µg/L)	1,2-Dichloro- ethane (EDC) (µg/L)	1,2 Dibromo- ethane (EDB) (µg/L)	Lead (µg/L)
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5
				01/23/2025	15	6.7	2.7	49	ND<0.50	1.3	19	48	39	ND<0.50	ND<0.0092	5.2
				01/31/2025	8.9	3.7	1.7	25	ND<0.50	0.94	7.3	29	22	ND<0.50	ND<0.0093	0.23 J
				02/15/2025	25	6.7	4.1	44	0.12 J	1.9	20	49	34	ND<0.50	ND<0.0095	ND<0.12
				02/24/2025	28	4.6	4.6	42	0.14 J	2.1	22	55	41	ND<0.50	ND<0.0094	0.15 J
				02/15/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	ND<0.12
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.50	ND<0.0094	0.17 J
				02/15/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.50	ND<0.0094	ND<0.12
				01/23/2025	20	51	32	640	ND<0.50	7.6	120	310	120	ND<0.50	ND<0.0093	0.23 J
				02/07/2025	0.35 J	2.3	1.2	46	ND<0.50	0.26 J	29	19	11	ND<0.50	ND<0.0094	0.75
				01/23/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	1.4
				02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.11 J	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.12 J	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.29 J
				03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				01/24/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				02/17/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	ND<0.12
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				01/24/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				02/17/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	0.22 J
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/17/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.20 J
				02/17/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0096	1.3
				01/27/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.19 J
				02/14/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	ND<0.12
				02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/04/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.29 J
				02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.19 J
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl- benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naph- thalene (µg/L)	1,2,4-Trimethyl- benzene (µg/L)	1,3,5-Trimethyl- benzene (µg/L)	1,2-Dichloro- ethane (EDC) (µg/L)	1,2 Dibromo- ethane (EDB) (µg/L)	Lead (µg/L)
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5
				02/15/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/03/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	41
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	3.9
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/05/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	0.66
				02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.95
				02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	0.55
				02/05/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	ND<0.12
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.14 J
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/04/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/04/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	1.1
				02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.12 J
				03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/03/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	0.68
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/04/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	2.1
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.38 J
				02/04/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/10/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.22 J

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L) 5	Toluene (µg/L) 1,000	Ethyl- benzene (µg/L) 700	Total Xylenes (µg/L) 10,000	MTBE (µg/L) 20	Isopropyl Benzene (µg/L) 840	Naph- thalene (µg/L) 100	1,2,4-Trimethyl- benzene (µg/L) 130	1,3,5-Trimethyl- benzene (µg/L) 130	1,2-Dichloro- ethane (EDC) (µg/L) 5	1,2 Dibromo- ethane (EDB) (µg/L) 0.05	Lead (µg/L) 5
DEP MSCs for a Residential, Used Aquifer																
				02/07/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	ND<0.12
				02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	ND<0.12
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	ND<0.12
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				01/27/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	0.12
				02/05/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	ND<0.12
				03/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				01/25/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	ND<0.12 B
				02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/05/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.13 J
				02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.16 J
				03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl- benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naph- thalene (µg/L)	1,2,4-Trimethyl- benzene (µg/L)	1,3,5-Trimethyl- benzene (µg/L)	1,2-Dichloro- ethane (EDC) (µg/L)	1,2 Dibromo- ethane (EDB) (µg/L)	Lead (µg/L)
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5
				01/23/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	0.17 J	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	0.31 J
				02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.16 J	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	0.17 J	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/03/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0092	0.34 J
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	1.2
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/03/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	0.40 J	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	0.32 J
				02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.47 J	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	1.2	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	1.3
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	0.16 J	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/08/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	0.16 J	ND<0.50	0.23 J	1.1	0.71	ND<0.50	ND<0.0094	ND<0.12
				02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.27 J	ND<0.10	ND<0.20	1.2	0.69	ND<0.10	ND<0.0095	ND<0.12
				03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	0.18 J	ND<0.13	ND<0.14	0.27 J	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				09/26/2023	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	-	-	-
				01/31/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				02/06/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.16 J

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl- benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naph- thalene (µg/L)	1,2,4-Trimethyl- benzene (µg/L)	1,3,5-Trimethyl- benzene (µg/L)	1,2-Dichloro- ethane (EDC) (µg/L)	1,2 Dibromo- ethane (EDB) (µg/L)	Lead (µg/L)
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5
				02/05/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	4.0
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	1.1
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				09/25/2023	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	-	-	-
				01/31/2025	39	7.9	49	230	0.2	18	160	ND<0.50	180	ND<0.50	ND<0.0094	ND<0.12
				01/31/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.63
				02/14/2025	92	80	41	310	0.33 J	13	110	280	120	ND<0.10	ND<0.0095	ND<0.12
				02/24/2025	58	9.4	ND<0.10	250	0.42 J	ND<0.10	140	450	200	ND<0.10	ND<0.0094	ND<0.12
				02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	ND<0.12
				01/31/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0092	ND<0.12
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0092	0.17 J
				02/05/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.52
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/06/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				01/31/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	ND<0.12
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/04/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	0.26 J
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.13 J
				03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/10/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	0.38 J
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	2.8
				03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.7
				03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L) 5	Toluene (µg/L) 1,000	Ethyl- benzene (µg/L) 700	Total Xylenes (µg/L) 10,000	MTBE (µg/L) 20	Isopropyl Benzene (µg/L) 840	Naph- thalene (µg/L) 100	1,2,4-Trimethyl- benzene (µg/L) 130	1,3,5-Trimethyl- benzene (µg/L) 130	1,2-Dichloro- ethane (EDC) (µg/L) 5	1,2 Dibromo- ethane (EDB) (µg/L) 0.05	Lead (µg/L) 5
DEP MSCs for a Residential, Used Aquifer																
				02/17/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	0.78
				02/06/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	0.78
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.36 J
				02/06/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.18 J
				03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/03/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.52
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.14 J
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	6.5
				02/03/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.20 J
				02/15/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	ND<0.12
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/07/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/08/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/05/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	ND<0.12
				03/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	3.0
				03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/13/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	0.14 J
				02/03/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	5.6
				03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/13/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				02/05/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0092	ND<0.12
				03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L) 5	Toluene (µg/L) 1,000	Ethyl- benzene (µg/L) 700	Total Xylenes (µg/L) 10,000	MTBE (µg/L) 20	Isopropyl Benzene (µg/L) 840	Naph- thalene (µg/L) 100	1,2,4-Trimethyl- benzene (µg/L) 130	1,3,5-Trimethyl- benzene (µg/L) 130	1,2-Dichloro- ethane (EDC) (µg/L) 5	1,2 Dibromo- ethane (EDB) (µg/L) 0.05	Lead (µg/L) 5
DEP MSCs for a Residential, Used Aquifer																
				02/04/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0096	0.33 J
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.54
				03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/04/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	ND<0.12
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/07/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				02/06/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	24
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	1.7
				02/14/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0097	0.16 J
				02/05/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.25 J
				03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/04/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.66 J
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	2.2
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.17 J
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.45 J	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	1.2
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.8 J
				02/13/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.13 J
				03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.5 J
				02/15/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L) 5	Toluene (µg/L) 1,000	Ethyl- benzene (µg/L) 700	Total Xylenes (µg/L) 10,000	MTBE (µg/L) 20	Isopropyl Benzene (µg/L) 840	Naph- thalene (µg/L) 100	1,2,4-Trimethyl- benzene (µg/L) 130	1,3,5-Trimethyl- benzene (µg/L) 130	1,2-Dichloro- ethane (EDC) (µg/L) 5	1,2 Dibromo- ethane (EDB) (µg/L) 0.05	Lead (µg/L) 5
DEP MSCs for a Residential, Used Aquifer																
				02/15/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/11/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/13/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	1.0
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	1.9
				02/13/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	ND<0.12
				02/03/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	ND<0.12
				02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	2.3
				02/10/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.86
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/10/2025	ND<0.19	0.29 J	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/05/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				02/14/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0096	ND<0.12
				02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	2.0
				02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/03/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.23 J
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L) 5	Toluene (µg/L) 1,000	Ethyl- benzene (µg/L) 700	Total Xylenes (µg/L) 10,000	MTBE (µg/L) 20	Isopropyl Benzene (µg/L) 840	Naph- thalene (µg/L) 100	1,2,4-Trimethyl- benzene (µg/L) 130	1,3,5-Trimethyl- benzene (µg/L) 130	1,2-Dichloro- ethane (EDC) (µg/L) 5	1,2 Dibromo- ethane (EDB) (µg/L) 0.05	Lead (µg/L) 5
DEP MSCs for a Residential, Used Aquifer																
				02/05/2025	0.85	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.80
				02/18/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	ND<0.12
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/04/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.73
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/11/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/13/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.63
				02/07/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	0.17 J
				02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.20 J
				02/14/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	2.5
				03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/05/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.76
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	0.91

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L) 5	Toluene (µg/L) 1,000	Ethyl- benzene (µg/L) 700	Total Xylenes (µg/L) 10,000	MTBE (µg/L) 20	Isopropyl Benzene (µg/L) 840	Naph- thalene (µg/L) 100	1,2,4-Trimethyl- benzene (µg/L) 130	1,3,5-Trimethyl- benzene (µg/L) 130	1,2-Dichloro- ethane (EDC) (µg/L) 5	1,2 Dibromo- ethane (EDB) (µg/L) 0.05	Lead (µg/L) 5
DEP MSCs for a Residential, Used Aquifer																
				02/10/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.66
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/03/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	0.65
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/10/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/06/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/12/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	1.3
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	1.7
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/08/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				02/15/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				03/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	0.23 J	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/06/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				02/14/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.60
				02/06/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/14/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/05/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	0.37 J
				03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/05/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.16 J
				03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J
				02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.24 J

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L) 5	Toluene (µg/L) 1,000	Ethyl- benzene (µg/L) 700	Total Xylenes (µg/L) 10,000	MTBE (µg/L) 20	Isopropyl Benzene (µg/L) 840	Naph- thalene (µg/L) 100	1,2,4-Trimethyl- benzene (µg/L) 130	1,3,5-Trimethyl- benzene (µg/L) 130	1,2-Dichloro- ethane (EDC) (µg/L) 5	1,2 Dibromo- ethane (EDB) (µg/L) 0.05	Lead (µg/L) 5
DEP MSCs for a Residential, Used Aquifer																
				02/17/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.19 J
				02/15/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	ND<0.12
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	220
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.7 J
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.44 J
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.4
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/07/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0092	ND<0.12
				03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	ND<0.12
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	2.2
				02/27/2025	ND<0.10	0.12 J	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.40 J
				03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.50 J
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.23 J
				02/07/2025	0.18 J	120	ND<0.50	ND<0.50	ND<0.50	0.12 J	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				02/18/2025	0.14 J	80	ND<0.10	ND<0.10	ND<0.10	0.11 J	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	2.3

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L) 5	Toluene (µg/L) 1,000	Ethyl- benzene (µg/L) 700	Total Xylenes (µg/L) 10,000	MTBE (µg/L) 20	Isopropyl Benzene (µg/L) 840	Naph- thalene (µg/L) 100	1,2,4-Trimethyl- benzene (µg/L) 130	1,3,5-Trimethyl- benzene (µg/L) 130	1,2-Dichloro- ethane (EDC) (µg/L) 5	1,2 Dibromo- ethane (EDB) (µg/L) 0.05	Lead (µg/L) 5
DEP MSCs for a Residential, Used Aquifer																
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.13 J
				03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J
				02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.20 J
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.6 J
				02/07/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0092	0.22 J
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.19 J
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.24 J
				02/18/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				03/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.17 J
				03/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	2.7
				02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0098	ND<0.12
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	ND<0.12
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/10/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/10/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl- benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naph- thalene (µg/L)	1,2,4-Trimethyl- benzene (µg/L)	1,3,5-Trimethyl- benzene (µg/L)	1,2-Dichloro- ethane (EDC) (µg/L)	1,2 Dibromo- ethane (EDB) (µg/L)	Lead (µg/L)
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5
				02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	4.2
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	9.7
				02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/06/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.41 J
				03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.6 J
				02/13/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/10/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.50 J
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/07/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L) 5	Toluene (µg/L) 1,000	Ethyl- benzene (µg/L) 700	Total Xylenes (µg/L) 10,000	MTBE (µg/L) 20	Isopropyl Benzene (µg/L) 840	Naph- thalene (µg/L) 100	1,2,4-Trimethyl- benzene (µg/L) 130	1,3,5-Trimethyl- benzene (µg/L) 130	1,2-Dichloro- ethane (EDC) (µg/L) 5	1,2 Dibromo- ethane (EDB) (µg/L) 0.05	Lead (µg/L) 5
DEP MSCs for a Residential, Used Aquifer																
				02/07/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.30 J	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	2.6
				02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.12 J
				02/07/2025	0.44 J	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.21 J
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/15/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	ND<0.12
				03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/15/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/13/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.32 J
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	ND<0.12
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J
				02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.14 J
				03/03/2025	ND<0.19	14	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.51 J
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.48 J
				02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	0.16 J
				03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/06/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	ND<0.12
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.15 J
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L) 5	Toluene (µg/L) 1,000	Ethyl- benzene (µg/L) 700	Total Xylenes (µg/L) 10,000	MTBE (µg/L) 20	Isopropyl Benzene (µg/L) 840	Naph- thalene (µg/L) 100	1,2,4-Trimethyl- benzene (µg/L) 130	1,3,5-Trimethyl- benzene (µg/L) 130	1,2-Dichloro- ethane (EDC) (µg/L) 5	1,2 Dibromo- ethane (EDB) (µg/L) 0.05	Lead (µg/L) 5
DEP MSCs for a Residential, Used Aquifer																
				02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	0.20 J
				02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/11/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.38 J
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/11/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	1.3
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/11/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.24 J
				02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.13 J
				03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.16 J
				03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.19 J
				03/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J
				02/15/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/12/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	0.52
				02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	1.4
				02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	1.3
				03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/13/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	2.3	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	3.2	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	1.2
				02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.13 J
				02/20/2025	ND<0.10	ND<0.10	ND<0.10	0.24 J	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	ND<0.12
				02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.40 J	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	0.39 J	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.11 J	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.10 J	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/13/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L) 5	Toluene (µg/L) 1,000	Ethyl- benzene (µg/L) 700	Total Xylenes (µg/L) 10,000	MTBE (µg/L) 20	Isopropyl Benzene (µg/L) 840	Naph- thalene (µg/L) 100	1,2,4-Trimethyl- benzene (µg/L) 130	1,3,5-Trimethyl- benzene (µg/L) 130	1,2-Dichloro- ethane (EDC) (µg/L) 5	1,2 Dibromo- ethane (EDB) (µg/L) 0.05	Lead (µg/L) 5
DEP MSCs for a Residential, Used Aquifer																
				02/13/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	1.8
				03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.9
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	1.6
				02/12/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	ND<0.12
				03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.014	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	0.34 J	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/13/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/13/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	1.7
				02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.16 J
				02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.6
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.2
				02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	1.2
				02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	1.8
				02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	1.5
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L) 5	Toluene (µg/L) 1,000	Ethyl- benzene (µg/L) 700	Total Xylenes (µg/L) 10,000	MTBE (µg/L) 20	Isopropyl Benzene (µg/L) 840	Naph- thalene (µg/L) 100	1,2,4-Trimethyl- benzene (µg/L) 130	1,3,5-Trimethyl- benzene (µg/L) 130	1,2-Dichloro- ethane (EDC) (µg/L) 5	1,2 Dibromo- ethane (EDB) (µg/L) 0.05	Lead (µg/L) 5
DEP MSCs for a Residential, Used Aquifer																
				02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/15/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.12 J
				03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	ND<0.12
				03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.12 J
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.7
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	1.3
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.6
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/13/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/13/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L) 5	Toluene (µg/L) 1,000	Ethyl- benzene (µg/L) 700	Total Xylenes (µg/L) 10,000	MTBE (µg/L) 20	Isopropyl Benzene (µg/L) 840	Naph- thalene (µg/L) 100	1,2,4-Trimethyl- benzene (µg/L) 130	1,3,5-Trimethyl- benzene (µg/L) 130	1,2-Dichloro- ethane (EDC) (µg/L) 5	1,2 Dibromo- ethane (EDB) (µg/L) 0.05	Lead (µg/L) 5
DEP MSCs for a Residential, Used Aquifer																
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.19 J
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.15 J
				02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/17/2025	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/17/2025	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	2.5
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.8 J
				02/25/2025	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.38 J
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	1.2
				02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.14 J
				02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.0
				02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.12 J
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.6 J
				03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0097	ND<0.12
				02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J
				02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/15/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	3.5
				03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	0.43 J
				03/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.1
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L) 5	Toluene (µg/L) 1,000	Ethyl- benzene (µg/L) 700	Total Xylenes (µg/L) 10,000	MTBE (µg/L) 20	Isopropyl Benzene (µg/L) 840	Naph- thalene (µg/L) 100	1,2,4-Trimethyl- benzene (µg/L) 130	1,3,5-Trimethyl- benzene (µg/L) 130	1,2-Dichloro- ethane (EDC) (µg/L) 5	1,2 Dibromo- ethane (EDB) (µg/L) 0.05	Lead (µg/L) 5
DEP MSCs for a Residential, Used Aquifer																
				02/15/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/13/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/15/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.61
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.0 J
				02/15/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.71
				03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.7 J
				02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.8 J
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	1.4
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.19 J
				03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	1.2

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L) 5	Toluene (µg/L) 1,000	Ethyl- benzene (µg/L) 700	Total Xylenes (µg/L) 10,000	MTBE (µg/L) 20	Isopropyl Benzene (µg/L) 840	Naph- thalene (µg/L) 100	1,2,4-Trimethyl- benzene (µg/L) 130	1,3,5-Trimethyl- benzene (µg/L) 130	1,2-Dichloro- ethane (EDC) (µg/L) 5	1,2 Dibromo- ethane (EDB) (µg/L) 0.05	Lead (µg/L) 5
DEP MSCs for a Residential, Used Aquifer				02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.16 J
				02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.55
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.18 J
				03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	7.2
				02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.39 J
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.55
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	0.18 J
				02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.8 J
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.34 J
				02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.017 J
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl- benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naph- thalene (µg/L)	1,2,4-Trimethyl- benzene (µg/L)	1,3,5-Trimethyl- benzene (µg/L)	1,2-Dichloro- ethane (EDC) (µg/L)	1,2 Dibromo- ethane (EDB) (µg/L)	Lead (µg/L)
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5
				02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/13/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.52
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Notes:
DEP = Pennsylvania Department of Environmental Protection
MSCs = Medium-Specific Concentrations per 25 Pa. Code Chapter 250
µg/L = Micrograms/Liter
ND<# = Not Detected (# is method detection limit)
NA = Not Available or Not Analyzed
MDL = Method Detection Limit
RL = Reporting Limit
PID = Photoionization Detector
ppm = Parts Per Million
J = Approximate value; result is < RL and ≥ MDL
* = See laboratory report for qualifiers
Bold = Exceeds the DEP MSC for a Used, Residential Aquifer < 2,500 mg/L total dissolved solids
Volatiles analyzed via EPA Method 524.2
EDB analyzed via EPA Method 8011 through 2/28/2025; samples collected beginning 3/1/2025 analyzed via EPA Method 504
Dissolved Lead analyzed via EPA Method 200.8



Liquid-Level Gauging Data Summary

Well Location	Date	Time of Day	Depth to LNAPL (ft.)	Depth to Water (ft.)	LNAPL Thickness (ft.)	Well Head Screening (ppm)	Comments
	1/28/2025	0918	Not measured	Not Measured		23.6	Could not get bailer past ~25 feet hitting obstruction.
	1/29/2025	-	Unable to measure	Unable to measure		38.5	Pump or obstruction at ~25 feet below top of casing.
	2/3/2025	-	29.05	34.12	5.07	117	Pump set at 100 feet below top of casing
	2/5/2025	0.41	28.32	33.37	5.05	61.7	Pump out 8.2 gallons LNAPL
	2/6/2025	-	29.27	29.38	0.11	-	-
	2/7/2025	-	29.17	29.21	0.04	93.1	-
	2/8/2025	-	29.08	29.15	0.07	-	-
	2/8/2025	-	29.14	29.31	0.17	-	-
	2/9/2025	11:44 AM	29.08	29.16	0.08	72.9	-
	2/9/2025	12:30 PM	30.46	30.51	0.05	-	-
	2/10/2025	9:30 AM	28.75	28.80	0.05	-	-
	2/11/2025	-	28.41	28.42	0.01	42	0% LEL
	2/12/2025	1:55 PM	27.93	27.95	0.02	28	Not recoverable with Bailer
	2/13/2025	8:45 AM	27.65	27.67	0.02	50	Not recoverable with Bailer
	2/14/2025	9:00 AM	27.81	27.83	0.02	6	Not recoverable with Bailer
	2/15/2025	10:55 AM	-	24.44	-	30.5	-
	2/17/2025	-	26.77	26.79	0.02	8.0	Not recoverable with Bailer
	2/18/2025	10:00 AM	26.70	26.72	0.02	12.0	-
	2/19/2025	11:35 AM	28.08	28.09	0.01	28.0	Not recoverable with Bailer
	2/20/2025	-	26.34	26.36	0.02	6.0	Not recoverable with Bailer
	2/21/2025	-	26.38	26.40	0.02	6.0	Not recoverable with Bailer
	2/22/2025	9:52 AM	26.27	26.29	0.02	12.0	Not recoverable with Bailer
	2/24/2025	-	26.53	26.55	0.02	47	Not recoverable with Bailer
	2/25/2025	-	26.30	26.32	0.02	30	Deployed absorbent sock
	2/26/2025	9:15 AM	26.52	26.53	0.01	7	Pulled and Replaced sock
	2/27/2025	9:25 AM	-	26.41	-	22	Pulled and Replaced sock
	2/28/2025	10:00 AM	-	26.81	-	3.0	Pulled and Replaced sock
	3/1/2025	11:05 AM	-	26.57	-	4	-
	3/3/2025	9:45 AM	-	27.49	-	5	Pulled and Replaced sock
	3/4/2025	-	-	27.19	-	7	Pulled and Replaced sock
	3/5/2025	-	-	27.14	-	3	-
	3/6/2025	-	-	27.11	-	2	-
	3/7/2025	-	-	26.42	-	1	-
	3/8/2025	-	-	26.10	-	0	-
	3/10/2025	10:00 AM	-	25.95	-	3	Pulled and Replaced sock (50%)
	3/11/2025	9:45 AM	-	26.21	-	1	Did not replace sock (<5%)
	3/12/2025	9:45 AM	-	26.15	-	1	Did not replace sock (<5%)
	3/13/2025	9:20 AM	-	26.38	-	3	Did not replace sock (<5%)
	3/14/2025	9:30 AM	-	26.62	-	3	Did not replace sock (10%)
	3/15/2025	11:29 AM	-	26.80	-	1	Pulled and Replaced sock
	3/17/2025	9:50 AM	-	26.96	-	3	Did not replace sock (<5%)



Liquid-Level Gauging Data Summary

Well Location	Date	Time of Day	Depth to LNAPL (ft.)	Depth to Water (ft.)	LNAPL Thickness (ft.)	Well Head Screening (ppm)	Comments
[REDACTED]	1/31/2025	1050	Not Measured	Not Measured		433.6	LNAPL present but bailer unable to be retrieved. Caught on wire.
	2/7/2025	-	72.21	84.55	12.34	376.8	Pump out 16.48 gallons LNAPL
	2/8/2025	-	64.54	64.64	0.10	-	
	2/8/2025	-	-	105.49	-	Not Measured	Gauging data inconsistent with previous measurements.
	2/9/2025	11:26 AM	72.91	72.98	0.07	296.7	-
	2/9/2025	12:00 PM	71.29	71.55	0.26	-	Less than an inch bailed out (0.12 gal)
	2/10/2025	10:00 AM	72.82	73.20	0.38	193	Bailed ~1 gallon of LNAPL
	2/10/2025	11:00 AM	71.56	71.80	0.24	-	Bailed <1 gallon of LNAPL
	2/11/2025	09:45 AM	65.78	66.24	0.46	328	Bailed ~1 gallon of LNAPL
	2/11/2025	10:10 AM	65.60	65.74	0.14	-	-
	2/12/2025	1:50 PM	87.59	88.01	0.42	395	Bailed 1.5 gallons of LNAPL
	2/12/2025	2:05 PM	87.18	87.35	0.17	-	-
	2/12/2025	2:08 PM	87.00	87.13	0.13	-	-
	2/13/2025	-	85.91	86.24	0.33	260	Bailed 0.5 gallons of LNAPL
	2/13/2025	-	85.39	85.47	0.08	-	-
	2/14/2025	9:05 AM	86.39	86.75	0.36	132	Bailed 0.5 gallons of LNAPL
	2/14/2025	-	85.85	85.94	0.09	-	-
	2/15/2025	9:30 AM	63.49	63.77	0.28	393	Bailed 0.5 gallons of LNAPL
	2/15/2025	-	63.52	63.58	0.06	-	Bailed approximately 2.5 gallons of LNAPL/water
	2/17/2025	-	58.53	59.01	0.48	199	Bailed approximately 1 gallon of LNAPL/water
	2/17/2025	-	58.71	58.81	0.10	-	-
	2/18/2025	9:30 AM	72.84	73.23	0.39	162	Bailed approximately 1/2 gallon of LNAPL/water
	2/18/2025	-	72.10	72.28	0.18	-	0% LEL
	2/19/2025	9:35 AM	64.66	65.04	0.38	286.0	Bailed approximately 0.2 gallons of LNAPL
	2/19/2025	3:05 PM	72.06	72.39	0.33	225.0	Bailed approximately 0.2 gallons of LNAPL
	2/20/2025	10:00 AM	62.20	62.71	0.51	286.0	Bailed approximately 1.5 gallons of LNAPL
	2/20/2025	1:30 PM	55.80	55.95	0.15	257.0	Bailed approximately 0.5 gallons of LNAPL
	2/21/2025	9:30 AM	61.89	62.04	0.15	132.0	Bailed approximately 0.25 gallons of LNAPL
	2/21/2025	-	61.84	61.92	0.08	-	-
	2/21/2025	1:30 PM	53.03	53.13	0.10	281.0	Bailed approximately 0.5 gallons of LNAPL
	2/21/2025	-	53.12	53.19	0.07	-	-
	2/22/2025	9:15 AM	48.79	49.03	0.24	186	Bailer string wrapped around drop tube and could not be retrieved without pulling pump. Homeowner was not home to turn off breaker so pump could not be pulled.
	2/22/2025	12:35 PM	62.42	62.66	0.24	188	
	2/23/2025	8:50 AM	37.51	37.82	0.31	154	No product bailed (see above)
	2/23/2025	9:50 AM	37.06	37.36	0.30	147	No product bailed (see above)
	2/24/2025	10:00 AM	70.28	70.70	0.42	418	Bailed approximately 0.5 gallons of LNAPL
	2/24/2025	1:50:00 PM	90.94	91.20	0.26	60	Bailed approximately 0.5 gallons of LNAPL
	2/24/2025	2:10:00 PM	90.13	90.24	0.11	-	-
	2/25/2025	9:35 AM	80.97	81.15	0.18	314	Bailed approximately 0.5 gallons of LNAPL
	2/25/2025	-	80.55	80.62	0.07	-	-
	2/25/2025	2:40 PM	65.44	65.55	0.11	322	Bailed approximately 0.5 gallons of LNAPL
	2/25/2025	-	65.21	65.25	0.04	-	-
	2/26/2025	9:25 AM	44.22	44.41	0.19	331	Bailed approximately 1 gallon of LNAPL
	2/26/2025	-	44.76	44.79	0.03	-	-
	2/26/2025	2:15:00 PM	40.76	40.81	0.05	107	Bailed approximately 0.5 gallon of LNAPL/water
	2/26/2025	-	41.22	41.24	0.02	-	-



Liquid-Level Gauging Data Summary

Well Location	Date	Time of Day	Depth to LNAPL (ft.)	Depth to Water (ft.)	LNAPL Thickness (ft.)	Well Head Screening (ppm)	Comments
	2/27/2025	9:40 AM	51.66	51.75	0.09	88	Bailed approximately 1 gallon of LNAPL
	2/27/2025	-	51.71	51.73	0.02	-	-
	2/27/2025	2:45 PM	57.17	57.19	0.02	204	Bailed approximately 0.5 gallon of LNAPL
	2/27/2025	-	57.10	57.11	0.01	-	-
	2/28/2025	9:00 AM	47.94	48.04	0.10	372	Bailed approximately 0.5 gallon of LNAPL
	2/28/2025	-	48.06	48.10	0.04	-	-
	2/28/2025	1:45 PM	42.62	42.70	0.08	323	Bailed approximately 0.5 gallon of LNAPL
	2/28/2025	-	42.87	42.90	0.03	-	-
	3/1/2025	9:00 AM	56.87	57.00	0.13	150	Bailed approximately 0.25 gallon of LNAPL
	3/1/2025	-	-	56.75	Sheen	-	-
	3/1/2025	1:00 PM	52.81	52.92	0.11	243	Bailed approximately 0.25 gallon of LNAPL
	3/1/2025	-	72.85	72.96	0.11	-	-
	3/2/2025	11:25 AM	70.26	70.42	0.16	-	Bailed approximately 0.25 gallon of LNAPL
	3/2/2025	-	69.68	69.80	0.12	-	-
	3/2/2025	12:55 PM	80.18	80.34	0.16	-	Bailed approximately 0.25 gallon of LNAPL
	3/2/2025	-	79.40	79.54	0.14	-	-
	3/3/2025	10:00 AM	71.40	71.62	0.22	97	Bailed approximately 0.5 gallon of LNAPL
	3/3/2025	-	71.19	71.26	0.07	-	-
	3/3/2025	1:35 PM	100.22	100.32	0.10	82	Bailed approximately 0.3 gallon of LNAPL
	3/3/2025	-	99.42	99.45	0.03	-	-
	3/4/2025	10:15 AM	57.68	57.78	0.10	155	Bailed approximately 0.25 gallon of LNAPL
	3/4/2025	-	57.59	57.62	0.03	-	-
	3/4/2025	1:35 PM	61.75	61.82	0.07	142	Bailed approximately 0.25 gallon of LNAPL
	3/4/2025	-	61.59	61.61	0.02	-	-
	3/5/2025	9:30 AM	76.76	76.87	0.11	160	Bailed approximately 0.25 gallon of LNAPL
	3/5/2025	-	76.19	76.22	0.03	-	-
	3/6/2025	9:40 AM	55.93	56.07	0.14	280	Bailed approximately 0.5 gallon of LNAPL
	3/6/2025	-	55.74	55.77	0.03	-	-
	3/6/2025	1:20 PM	50.07	50.09	0.02	-	-
	3/7/2025	9:00 AM	76.40	76.55	0.15	325	Bailed approximately 0.5 gallon of LNAPL
	3/7/2025	-	75.89	75.91	0.02	-	-
	3/7/2025	1:10 PM	76.49	76.53	0.04	193	Bailed approximately 0.5 gallon of LNAPL
	3/7/2025	-	76.03	76.04	0.01	-	-
	3/8/2025	10:40 AM	51.51	51.65	0.14	275	Bailed approximately 1 gallon of LNAPL
	3/8/2025	-	51.43	51.48	0.05	-	-
	3/8/2025	1:10 PM	48.15	48.27	0.12	269	Bailed approximately 1 gallon of LNAPL
	3/8/2025	-	48.29	48.31	0.02	-	-
	3/9/2025	11:20 AM	61.31	61.46	0.15	-	Bailed approximately 0.25 gallon of LNAPL
	3/9/2025	-	60.94	61.06	0.12	-	-
	3/9/2025	1:10 PM	58.22	58.38	0.16	-	Bailed approximately 0.25 gallon of LNAPL
	3/9/2025	-	57.91	58.06	0.15	-	-
	3/10/2025	9:30 AM	66.42	66.68	0.26	-	Bailed approximately 0.5 gallon of LNAPL
	3/10/2025	-	66.15	66.18	0.03	-	-
	3/10/2025	1:30 PM	57.44	57.52	0.08	334	Bailed approximately 0.5 gallon of LNAPL
	3/10/2025	-	57.49	57.50	0.01	-	-
	3/11/2025	9:20 AM	52.00	52.11	0.11	376	Bailed approximately 1.0 gallon of LNAPL/groundwater
	3/11/2025	-	52.05	52.07	0.02	-	-
	3/11/2025	1:20 PM	46.10	46.13	0.03	377	Bailed approximately 0.5 gallon of LNAPL
	3/11/2025	-	46.23	46.24	0.01	-	-
	3/12/2025	9:20 AM	55.52	55.64	0.12	349	Bailed approximately 0.5 gallon of LNAPL/groundwater
	3/12/2025	-	55.41	55.42	0.01	-	-



Liquid-Level Gauging Data Summary

Well Location	Date	Time of Day	Depth to LNAPL (ft.)	Depth to Water (ft.)	LNAPL Thickness (ft.)	Well Head Screening (ppm)	Comments
	3/12/2025	1:10 PM	48.10	48.13	0.03	257	Bailed approximately 0.25 gallon of LNAPL/groundwater
	3/12/2025	-	48.13	48.14	0.01	-	-
	3/13/2025	9:00 AM	35.18	35.29	0.11	394	Bailed approximately 0.5 gallon of LNAPL/groundwater
	3/13/2025	-	35.49	35.50	0.01	-	-
	3/13/2025	1:40 PM	75.32	75.35	0.03	103	Bailed approximately 0.5 gallon of LNAPL/groundwater
	3/13/2025	-	74.99	75.00	0.01	-	-
	3/14/2025	9:00 AM	58.98	59.04	0.06	448	Bailed approximately 0.5 gallon of LNAPL/groundwater
	3/14/2025	-	58.87	58.88	0.01	-	-
	3/14/2025	1:30 PM	49.58	49.66	0.08	314	Bailed approximately 0.5 gallon of LNAPL/groundwater
	3/14/2025	-	49.71	49.72	0.01	-	-
	3/15/2025	9:40 AM	35.52	35.60	0.08	355	Bailed approximately 1.25 gallon of LNAPL/groundwater
	3/15/2025	-	35.37	35.39	0.02	-	-
	3/15/2025	11:06 AM	35.85	35.88	0.03	73	Bailed approximately 0.5 gallon of LNAPL/groundwater
	3/15/2025	-	36.12	36.13	0.01	-	-
	3/16/2025	8:50 AM	46.08	46.11	0.03	236	Bailed approximately 0.5 gallon of LNAPL/groundwater
	3/16/2025	-	46.10	46.11	0.01	-	-
	3/16/2025	9:50 AM	44.76	44.78	0.02	223	Bailed approximately 0.5 gallon of LNAPL/groundwater
	3/16/2025	-	44.80	44.81	0.01	-	-
	3/17/2025	9:15 AM	51.12	51.22	0.10	189	Bailed approximately 0.5 gallon of LNAPL/groundwater
	3/17/2025	-	51.09	51.10	0.01	-	-
	3/17/2025	13:15 PM	56.08	56.13	0.05	163	Bailed approximately 0.5 gallon of LNAPL/groundwater
	3/17/2025	-	55.85	55.86	0.01	-	-



Liquid-Level Gauging Data Summary

Well Location	Date	Time of Day	Depth to LNAPL (ft.)	Depth to Water (ft.)	LNAPL Thickness (ft.)	Well Head Screening (ppm)	Comments
[REDACTED]	1/29/2025	-	50.99	51.00	0.01	22.1	LNAPL darker in color than other LNAPL found.
	2/10/2025	1300	-	51.58	-	13.0	Bailer was clear
	2/17/2025	-	-	34.68	-	3.0	Bailer was clear
	2/18/2025	-	-	32.56	-	2.0	Bailer was clear; 0% LEL
	2/19/2025	12:00 PM	-	29.60	-	9.0	-
	2/20/2025	-	-	28.50	-	8.0	-
	2/21/2025	-	-	30.92	-	2.0	-
	2/22/2025	9:35 AM	-	27.72	-	22	-
	2/24/2025	12:00 PM	-	26.54	-	4.0	-
	2/25/2025	-	-	26.54	-	3.0	-
	2/26/2025	-	-	27.73	-	12	-
	2/27/2025	-	-	27.84	-	11	-
	2/28/2025	-	-	27.93	-	3.0	-
	3/1/2025	11:40 AM	-	29.49	-	4	-
	3/3/2025	-	-	32.26	-	2	-
	3/4/2025	-	-	43.74	-	1	-
	3/5/2025	-	-	35.89	-	29	-
	3/6/2025	-	-	29.25	-	9	-
	3/7/2025	-	-	28.64	-	4	-
	3/8/2025	-	-	27.38	-	0	-
	3/10/2025	10:30 AM	-	26.51	-	4	-
	3/11/2025	10:05 AM	-	31.60	-	4	-
	3/12/2025	10:00 AM	-	25.58	-	4	-
	3/13/2025	9:45 AM	-	26.61	-	3	-
	3/14/2025	9:50 AM	-	26.31	-	7	-
	3/15/2025	10:42 AM	-	26.14	-	1	-
	3/17/2025	10:12 AM	-	28.92	-	2	-



Liquid-Level Gauging Data Summary

Well Location	Date	Time of Day	Depth to LNAPL (ft.)	Depth to Water (ft.)	LNAPL Thickness (ft.)	Well Head Screening (ppm)	Comments
[REDACTED]	1/23/2025	-	Not Measured	Not Measured		21.0	LNAPL split sample with PADEP
	1/29/2025	1020	79.31	80.27	0.96	30.5	-
	2/10/2025	-	117.98	118.19	0.21	3.0	Approximately 0.01 gal bailed
	2/12/2025	2:51 PM	68.89	69.35	0.46	-	Bailed ~1 gallon of LNAPL
	2/12/2025	3:08 PM	68.20	68.39	0.19	-	-
	2/13/2025	10:40 AM	60.89	61.12	0.23	43	Bailed 0.5 gallons of LNAPL
	2/13/2025	11:50 AM	63.67	63.73	0.06	-	-
	2/14/2025	9:30 AM	58.69	58.75	0.06	6	Not recoverable with Bailer
	2/15/2025	11:10 AM	67.01	67.06	0.05	23.7	Bailed ~1 gallon of LNAPL / water
	2/15/2025	-	66.29	66.30	0.01	-	Not recoverable with Bailer
	2/17/2025	-	-	32.56	-	25	-
	2/18/2025	-	53.40	53.45	0.05	8.0	Not recoverable with Bailer; 0% LEL
	2/19/2025	12:10 PM	61.69	61.71	0.02	21.0	Not recoverable with Bailer
	2/20/2025	-	49.64	49.65	0.01	20.0	Not recoverable with Bailer
	2/21/2025	-	51.26	51.28	0.02	2.0	Not recoverable with Bailer
	2/22/2025	9:43 AM	52.25	52.26	0.01	15	Not recoverable with Bailer
	2/24/2025	11:40 AM	52.23	52.24	0.01	35	Not recoverable with Bailer
	2/25/2025	-	49.55	49.57	0.02	41	Deployed absorbent sock
	2/26/2025	-	51.96	51.97	0.01	7	Pulled and Replaced sock
	2/27/2025	-	-	47.77	-	41	Pulled and Replaced sock
	2/28/2025	-	-	54.79	-	7	-
	3/1/2025	-	-	52.95	-	8	-
	3/3/2025	-	-	47.76	-	12	Pulled and Replaced sock
	3/4/2025	-	-	49.29	-	3	-
	3/5/2025	-	-	47.14	-	8	Pulled and Replaced sock
	3/6/2025	-	-	52.12	-	2	-
	3/7/2025	-	-	47.10	-	6	-
	3/8/2025	-	-	47.48	-	2	-
	3/10/2025	10:35 AM	-	51.12	-	4	Sock was not replaced (10%)
	3/11/2025	9:55 AM	-	46.73	-	1	Pulled and Replaced sock (40%)
	3/12/2025	8:40 AM	-	44.51	-	9	Sock was removed and not replaced
	3/13/2025	9:35 AM	-	48.62	-	8	-
	3/14/2025	9:40 AM	-	48.28	-	7	-
	3/15/2025	10:37 AM	-	45.41	-	7	-
	3/17/2025	10:06 AM	-	45.62	-	1	-



Liquid-Level Gauging Data Summary

Well Location	Date	Time of Day	Depth to LNAPL (ft.)	Depth to Water (ft.)	LNAPL Thickness (ft.)	Well Head Screening (ppm)	Comments
	1/28/2025	-	Approximately 55	Not Measured		82.2	Checked with bailer, pale yellow
	1/29/2025	10:00 AM	55.61	62.55	6.94	397.1	-
	2/7/2025	-	63.92	69.60	5.68	81.9	-
	2/10/2025	12:25 PM	64.69	70.28	5.59	94	Pump out 12 gallons LNAPL
	2/11/2025	-	57.65	57.67	0.02	188	0% LEL
	2/12/2025	-	-	62.15	-	73	-
	2/13/2025	-	59.12	59.13	0.01	97	Not recoverable with Bailer
	2/14/2025	9:40 AM	62.79	62.80	0.01	25	Not recoverable with Bailer
	2/15/2025	11:45 AM	-	61.15	-	393.8	-
	2/17/2025	9:45 AM	-	57.00	-	-	-
	2/18/2025	8:10 AM	52.68	52.69	0.01	0.0	Not recoverable with Bailer; 0% LEL
	2/19/2025	12:04 PM	51.83	51.84	0.01	22.0	Not recoverable with Bailer
	2/20/2025	-	-	50.94	-	26.0	-
	2/21/2025	-	50.08	50.11	0.03	31.0	Not recoverable with Bailer
	2/22/2025	9:30 AM	48.99	49.00	0.01	124	Not recoverable with Bailer
	2/24/2025	11:50 AM	48.03	48.05	0.02	69	Not recoverable with Bailer
	2/25/2025	-	47.32	47.35	0.03	38	Deployed absorbent sock
	2/26/2025	-	-	47.78	-	14	Pulled and Replaced sock with 2 new socks
	2/27/2025	-	-	47.60	-	171	Pulled and Replaced 2 socks
	2/28/2025	-	-	47.55	-	5	Pulled and Replaced 2 socks
	3/1/2025	-	-	37.35	-	4	-
	3/3/2025	-	-	48.40	-	49	Pulled and Replaced 2 socks
	3/4/2025	-	-	48.21	-	25	-
	3/5/2025	-	-	47.78	-	14	Pulled and Replaced 2 socks
	3/6/2025	-	-	47.70	-	2	-
	3/7/2025	-	-	48.30	-	8	-
	3/8/2025	-	49.32	49.33	0.01	1	Biosludge on absorbent socks; LNAPL not observed
	3/10/2025	10:45 AM	-	48.53	-	5	Sock not replaced (5%)
	3/11/2025	7:35 AM	47.82	47.83	0.01	93	Socks removed (50%) for packer testing
	3/12/2025	-	-	-	-	-	NM due to packer testing
	3/13/2025	-	-	-	-	-	NM due to packer testing
	3/14/2025	-	-	-	-	-	NM due to packer testing
	3/15/2025	-	-	-	-	-	NM due to packer testing
	3/17/2025	-	-	-	-	-	NM due to packer testing

Notes:
ft. = feet
LNAPL = Light Non-Aqueous Phase Liquid
LEL - Lower Explosive Limit
NA = Not Applicable
Well head screening is completed with a photoionization detector (PID).

Wellhead Screening Summary Table

Address	Date	Wellhead PID Reading (ppm)	Wellhead check observations / Comments
	1/23/2025	0.0	Bailer check clear; approximately 58 feet to water
	2/12/2025	0.0	Bailer check clear
	1/23/2025	0.0	Bailer check clear; approximately 58 feet to water
	1/23/2025	0.0	Bailer check clear; approximately 180 feet to water
	1/23/2025	0.0	Bailer check clear; approximately 160 feet to water
	1/23/2025	21.0	LNAPL sampled collected on 1/23/25; See Gauging Table for additional data
	1/23/2025	0.0	Bailer check clear; approximately 89 feet to water
	1/23/2025	82.2	on 1/28/25 - LNAPL present; See Gauging Table for additional detail
	1/29/2025	0.0	Unable to conduct bailer check due to thick brush
	2/19/2025	0.0	Pump pulled; bailer check clear
	1/24/2025	0.0	Obstruction at 20 ft with bailer; pulled pump on 2/3/25, no LNAPL; DTW = 59.01 ft
	1/24/2025	PID not collected	LNAPL detected on 1/29/25; DTP = 50.99; DTW = 51.00 ft
	1/29/2025	22.1	LNAPL = 0.01 ft (see Gauging table)
	1/24/2025	-	Wellhead screen added to SOP on 1/28/2025
	1/24/2025	-	Wellhead screen added to SOP on 1/28/2025
	1/24/2025	-	Wellhead screen added to SOP on 1/28/2025
	2/17/2025	0.0	Bailer check clear
	1/25/2025	-	Wellhead screen added to SOP on 1/28/2025
	1/27/2025	-	Wellhead screen added to SOP on 1/28/2025
	1/27/2025	-	Wellhead screen added to SOP on 1/28/2025
	1/28/2025	-	Land Owner declined wellhead screening
	1/28/2025	-	Wellhead not screened
	1/28/2025	23.6 pm 1/28; 38.5 on 1/29/25	Wellhead screened: 38.5 ppm (on 1/29/25); attempted to check with microbailer, could not get past 25 feet; pulled pump on 2/3/25; DTP = 29.05 ft, DTW = 34.12 ft; well head screened = 117 ppm
	2/15/2025	110.0	See Gauging Table for additional data
	1/28/2025	0.0	Bailer check added to SOP 2/18/25
	1/28/2025	0.0	Bailer check added to SOP 2/18/25

Wellhead Screening Summary Table

Address	Date	Wellhead PID Reading (ppm)	Wellhead check observations / Comments
	1/29/2025	0.0	Bailer check added to SOP 2/18/25
	1/29/2025	-	Per LO, her well cap was just replaced and would prefer that it is not opened unless absolutely necessary
	1/30/2025	0.0	No bailer test due to obstruction at 20 feet
	1/31/2025	433.6	LNAPL in bailer, but bailer got stuck; 433.6 ppm at wellhead
	2/14/2025	-	See Gauging Table for additional data
	1/31/2025	0.0	Bailer check added to SOP 2/18/25
	1/31/2025	0.0	Bailer check added to SOP 2/18/25
	2/6/2025	0.0	Bailer check added to SOP 2/18/25
	1/31/2025	0.0	Bailer check added to SOP 2/18/25
	1/31/2025	0.0	Bailer check added to SOP 2/18/25
	1/31/2025	0.0	Bailer check added to SOP 2/18/25
	2/3/2025	0.0	Bailer check added to SOP 2/18/25
	2/3/2025	0.0	Bailer check added to SOP 2/18/25
	2/3/2025	0.0	Two well head bolts sheared off when attempting to remove screws. Did not measure in well w/ PID- took measurement at edge of the lid
	2/3/2025	0.0	Bailer check added to SOP 2/18/25
	2/3/2025	-	Well head under metal vault
	2/3/2025	-	Buried potable well, not checked; Irrigation well = 0.0 ppm
	2/14/2025	0.0	Bailer check added to SOP 2/18/25
	2/3/2025	0.0	Bailer check added to SOP 2/18/25
	2/3/2025	0.0	Bailer check added to SOP 2/18/25
	2/3/2025	0.0	Bailer check added to SOP 2/18/25
	2/3/2025	0.0	Bailer check added to SOP 2/18/25
	2/3/2025	-	Could not open well lid to screen
	2/14/2025	0.0	Bailer check added to SOP 2/18/25
	2/15/2025	-	Bolts were new on well head; inspected well and saw it was recaulked, did not attempt to open
	2/3/2025	0.0	Bailer check added to SOP 2/18/25
	2/4/2025	-	Wellhead not screened; unknown reason

Wellhead Screening Summary Table

Address	Date	Wellhead PID Reading (ppm)	Wellhead check observations / Comments
	2/4/2025	0.0	Bailer check added to SOP 2/18/25
	2/17/2025	0.0	Bailer check added to SOP 2/18/25
	2/4/2025	0.0	Bailer check added to SOP 2/18/25
	2/4/2025	-	Wellhead not screened
	2/4/2025	0.0	Bailer check added to SOP 2/18/25
	2/4/2025	0.0	Bailer check added to SOP 2/18/25
	2/4/2025	0.0	Bailer check added to SOP 2/18/25
	2/4/2025	0.0	Bailer check added to SOP 2/18/25
	2/4/2025	0.0	Bailer check added to SOP 2/18/25
	2/4/2025	0.0	Bailer check added to SOP 2/18/25
	2/4/2025	0.0	Bailer check added to SOP 2/18/25
	2/4/2025	0.0	Bailer check added to SOP 2/18/25
	2/4/2025	0.0	Bailer check added to SOP 2/18/25
	2/4/2025	0.0	Bailer check added to SOP 2/18/25
	2/5/2025	0.0	Wellhead not screened; unknown reason
	2/5/2025	0.0	Bailer check added to SOP 2/18/25
	2/5/2025	0.0	Bailer check added to SOP 2/18/25
	2/5/2025	0.0	Bailer check added to SOP 2/18/25
	2/5/2025	0.0	Wellhead check on 2/9/25
	2/9/2025	0.0	Wellhead check on 2/9/25; check w/ a bailer = no LNAPL
	2/18/2025	0.0	Wellhead check w/ a bailer = no LNAPL
	2/5/2025	0.0	Bailer check added to SOP 2/18/25
	2/5/2025	-	Wellhead not screened
	2/5/2025	0.0	Bailer check added to SOP 2/18/25
	2/5/2025	0.0	Bailer check added to SOP 2/18/25
	2/5/2025	0.0	On 2/12/25, located wellhead = 0.0 ppm; bailer check = no LNAPL
	2/14/2025	0.0	Bailer check = no LNAPL
	2/5/2025	-	Wellhead not screened
	2/5/2025	0.0	Bailer check added to SOP 2/18/25
	2/5/2025	0.0	Bailer check added to SOP 2/18/25
	2/5/2025	0.0	Bailer check added to SOP 2/18/25
	2/5/2025	0.0	Bailer check added to SOP 2/18/25

Wellhead Screening Summary Table

Address			Date	Wellhead PID Reading (ppm)	Wellhead check observations / Comments
			2/6/2025	-	Wellhead not screened
			2/6/2025	0.0	There is an unused well in the backyard- screened with PID 0.0
			2/7/2025	0.0	Bailer check added to SOP 2/18/25
			2/6/2025	0.0	Bailer check added to SOP 2/18/25
			2/6/2025	0.0	Bailer check added to SOP 2/18/25
			2/6/2025	-	Wellhead not screened
			2/6/2025	0.0	Bailer check added to SOP 2/18/25
			2/6/2025	-	Wellhead not screened; unknown reason
			2/6/2025	0.0	Bailer check added to SOP 2/18/25
			2/6/2025	-	Wellhead not screened
			2/7/2025	0.0	Bailer check added to SOP 2/18/25
			2/7/2025	0.0	Bailer check added to SOP 2/18/25
			2/7/2025	0.0	Bailer check added to SOP 2/18/25
			2/7/2025	0.0	Bailer check added to SOP 2/18/25
			2/7/2025	0.0	Bailer check added to SOP 2/18/25
			2/7/2025	0.0	Bailer check added to SOP 2/18/25
			2/7/2025	0.0	Bailer check added to SOP 2/18/25
			2/7/2025	0.0	Bailer check added to SOP 2/18/25
			2/7/2025	0.0	Bailer check added to SOP 2/18/25
			2/7/2025	0.0	Bailer check added to SOP 2/18/25
			2/7/2025	0.1	Bailer check added to SOP 2/18/25
			2/18/2025	0.0	Bailer check clear
			2/7/2025	0.0	Bailer check added to SOP 2/18/25
			2/8/2025	0.0	Bailer check added to SOP 2/18/25
			2/8/2025	-	Bolts sheared off when attempting to get the headspace readings on both wells. Will need to be tapped in order to access.
			2/8/2025	-	Wellhead to be located
			2/18/2025	0.0	Bailer check clear
			2/8/2025	-	Wellhead checked on 2/18/25

Wellhead Screening Summary Table

Address	Date	Wellhead PID Reading (ppm)	Wellhead check observations / Comments
	2/18/2025	0.0	Spacer in well prevented using bailer; PID was taken with well cap on, but tubing inside well casing
	2/8/2025	-	Broke bolts on well casing, unable to access to screen headspace.
	2/10/2025	0.0	Bailer check added to SOP 2/18/25
	2/10/2025	0.0	Bailer check added to SOP 2/18/25
	2/10/2025	0.0	Bailer check added to SOP 2/18/25
	2/10/2025	0.0	Bailer check added to SOP 2/18/25
	2/10/2025	0.0	Bailer check added to SOP 2/18/25
	2/10/2025	0.0	Well bolts are rusted on and can't be removed without breaking and the well lid wouldn't come off. Took the PID reading from the crack where the conduit goes
	2/10/2025	0.0	Bailer check added to SOP 2/18/25
	2/10/2025	0.0	Two bolts on the well lid were already stripped off so the well lid could not be removed. Collected PID reading from the sapce between the conduit and the well lid. Homeowners are aware
	2/10/2025	0.0	Bailer check added to SOP 2/18/25
	2/11/2025	0.0	Bailer check added to SOP 2/18/25
	2/11/2025	1) 0.0 2) 0.0 3) 0.0	Bailer check added to SOP 2/18/25
	2/11/2025	0.0	Bailer check added to SOP 2/18/25
	2/11/2025	0.0	Bailer check added to SOP 2/18/25
	2/11/2025	0.0	Bailer check added to SOP 2/18/25
	2/11/2025	0.0	Bailer check added to SOP 2/18/25
	2/12/2025	0.0	Bailer check added to SOP 2/18/25
	2/12/2025	0.0	Bailer check added to SOP 2/18/25
	2/12/2025	0.0	Bailer check added to SOP 2/18/25
	2/12/2025	0.0	Bailer check added to SOP 2/18/25
	2/13/2025	0.0	Bailer check added to SOP 2/18/25
	2/13/2025	0.0	Bailer check added to SOP 2/18/25

Wellhead Screening Summary Table

Address	Date	Wellhead PID Reading (ppm)	Wellhead check observations / Comments
	2/13/2025	0.0	Bailer check added to SOP 2/18/25
	2/13/2025	0.0	Bailer check added to SOP 2/18/25
	2/13/2025	0.0	Bailer check added to SOP 2/18/25
	2/13/2025	-	Could not locate well
	2/13/2025	0.0	Bailer check added to SOP 2/18/25
	2/13/2025	0.0	Bailer check added to SOP 2/18/25
	2/13/2025	0.0	0.0 ppm at the well head; measurement taken through conduit
	2/13/2025	0.0	Bailer check added to SOP 2/18/25
	2/13/2025	0.0	Bailer check added to SOP 2/18/25
	2/13/2025	0.0	Bailer check added to SOP 2/18/25
	2/13/2025	-	well buried 6ft underground- unable to take PID measurement
	2/13/2025	0.0	Bailer check added to SOP 2/18/25
	2/13/2025	-	Well located under patio- unable to take PID measurement
	2/13/2025	-	Could not open well due to stuck bolt
	2/13/2025	0.0	Bailer check added to SOP 2/18/25
	2/13/2025	0.0	Bailer check added to SOP 2/18/25
	2/13/2025	-	Could not open well
	2/14/2025	0.0	Bailer check added to SOP 2/18/25
	2/14/2025	-	Well is buried under brick in backyard off the porch about 10 ft
	2/14/2025	0.0 / 0.0	2 wells on the property; one is a supply well, other is for irrigation system. The irrigation system is currently off. It is unknown which well head is for irrigation system.
	2/14/2025	0.0	Bailer check added to SOP 2/18/25
	2/14/2025	0.0	Bailer check added to SOP 2/18/25
	2/14/2025	0.0	Bailer check added to SOP 2/18/25
	2/14/2025	-	Unable to access. Well head has a sanitary seal.
	2/14/2025	0.0	Bailer check added to SOP 2/18/25
	2/15/2025	0.0	Bailer check added to SOP 2/18/25

Wellhead Screening Summary Table

Address	Date	Wellhead PID Reading (ppm)	Wellhead check observations / Comments
	2/14/2025	-	When removing well head all 3 bolts broke off. Well not screened; can't continue or well can't be sealed.
	2/14/2025	0.0	Bailer check added to SOP 2/18/25
	2/14/2025	0.0	Bailer check added to SOP 2/18/25
	2/14/2025	0.0	Bailer check added to SOP 2/18/25
	2/14/2025	-	Could not locate well. Owner stated well was buried about 4ft underground in front yard
	2/14/2025	0.0	Bailer check added to SOP 2/18/25
	2/15/2025	0.0	Bailer check added to SOP 2/18/25
	2/15/2025	0.0	Bailer check added to SOP 2/18/25
	2/15/2025	0.0	Bailer check added to SOP 2/18/25
	2/15/2025	0.0	Bailer check added to SOP 2/18/25
	2/15/2025	-	Well access is under a concrete pad; unable to open and gain access to the well
	2/15/2025	0.0	Bailer check added to SOP 2/18/25
	2/15/2025	-	Well is buried under concrete pad
	2/15/2025	0.0	Bailer check added to SOP 2/18/25
	2/15/2025	0.0	Bailer check added to SOP 2/18/25
	2/15/2025	0.0	Bailer check added to SOP 2/18/25
	2/15/2025	0.0	Bailer check added to SOP 2/18/25
	2/15/2025	-	Unable to access well
	2/15/2025	-	Unable to access well; buried under gravel
	2/15/2025	0.0	Bailer check added to SOP 2/18/25
	2/15/2025	0.0	Bailer check added to SOP 2/18/25
	2/17/2025	0.0	Bailer check added to SOP 2/18/25
	2/17/2025	-	PID reading collected, not documented
	2/17/2025	0.0	0.0 ppm at the wellhead
	2/17/2025	0.0 to 0.1	Bailer check added to SOP 2/18/25
	2/17/2025	0.0	Bailer check added to SOP 2/18/25
	2/17/2025	0.0	0.0 ppm at the wellhead; well casing is rusted open on sides
	2/17/2025	-	NA- need to remove bush roots system

Wellhead Screening Summary Table

Address	Date	Wellhead PID Reading (ppm)	Wellhead check observations / Comments
	2/17/2025	-	Well does not have cap/access
	2/17/2025	-	Could not open; well has sanitary seal
	2/17/2025	0.2	Could not access with bailer
	2/17/2025	-	Well accessed on 2/19/25
	2/19/2025	0.0	Bailer Test 0.0; no LNAPL
	2/17/2025	0.0	Bailer check added to SOP 2/18/25
	2/17/2025	-	Could not open; well has sanitary seal and is in a confined space
	2/17/2025	0.2	Bailer check added to SOP 2/18/25
	2/17/2025	0.0	Bailer check added to SOP 2/18/25
	2/17/2025	-	well head in basement unable to open
	2/17/2025	-	Well is buried
	2/17/2025	0.0	Bailer check added to SOP 2/18/25
	2/17/2025	-	NA- Well cap sealed, cannot access
	2/17/2025	-	Bailer check added to SOP 2/18/25
	2/17/2025	-	Filtration system was being installed at time of sampling
	2/17/2025	0.0	Bailer became stuck in well.
	2/17/2025	0.0	Bailer check added to SOP 2/18/25
	2/17/2025	0.0	Bailer check added to SOP 2/18/25
	2/17/2025	0.0	Bailer check added to SOP 2/18/25
	2/17/2025	0.0	Bailer check clear
	2/17/2025	0.0	Bailer check added to SOP 2/18/25
	2/18/2025	0.0	Bailer check clear
	2/18/2025	0.0	Bailer check clear
	2/18/2025	0.0	Bailer check clear
	2/18/2025	-	Bailer stuck in well
	2/18/2025	-	Bailer check clear
	2/18/2025	0.0	Bailer check clear
	2/18/2025	0.0	Bailer check clear
	2/18/2025	0.0	Bailer check clear
	2/18/2025	0.0	Bailer check clear

Wellhead Screening Summary Table

Address		Date	Wellhead PID Reading (ppm)	Wellhead check observations / Comments
		2/18/2025	-	Bailer check clear
		2/18/2025	0.0	Bailer check clear
		2/18/2025	-	Wellhead not accessible
		2/18/2025	0.0	Bailer check clear
		2/18/2025	0.0	Bailer check clear
		2/18/2025	0.0	Bailer check clear
		2/18/2025	0.0	Bailer check clear
		2/18/2025	0.0	Bailer check clear
		2/18/2025	0.0	Bailer check clear
		2/18/2025	0.0	Well is buried
		2/18/2025	0.0	Bailer check clear
		2/18/2025	0.0	Bailer check clear
		2/18/2025	0.0	Unable to remove well seal
		2/18/2025	0.0	Bailer check clear
		2/18/2025	0.0	Bailer check clear
		2/18/2025	-	Well location is unknown
		2/19/2025	-	Bailer check clear
		2/19/2025	0.0	Bailer check clear
		2/19/2025	0.0	Bailer check clear
		2/19/2025	0.0	Bailer check clear
		2/19/2025	0.0	Bailer check clear
		2/19/2025	0.0	Spacers blocked bailer
		2/19/2025	0.0	Bailer check clear
		2/19/2025	-	Well is unable to be accessed
		2/19/2025	0.0	Bailer check clear
		2/19/2025	0.0	Spacer blocked bailer
		2/19/2025	-	Well is inaccessible (in a wishing well)
		2/19/2025	0.0	Bailer check clear
		2/19/2025	0.0	Bailer check clear
		2/19/2025	0.0	Bailer check clear
		2/19/2025	0.0	Bailer check clear
		2/19/2025	0.0	Spacer blocked bailer
		2/19/2025	0.0	Spacer blocked bailer

Wellhead Screening Summary Table

Address	Date	Wellhead PID Reading (ppm)	Wellhead check observations / Comments
	2/19/2025	-	Unable to open well
	2/19/2025	-	Unable to open well (due to new sanitary seal)
	2/20/2025	0.0	Bailer check clear
	2/20/2025	0.0	Bailer check clear
	2/20/2025	0.0	Bailer check clear
	2/20/2025	0.0	Spacer blocked bailer
	2/20/2025	-	Unable to open well
	2/20/2025	0.0	Unable to open well
	2/20/2025	0.0	Bailer check clear
	2/20/2025	6.3	Bailer check clear
	2/20/2025	-	Unable to open well
	2/20/2025	-	Unable to open well
	2/20/2025	0.0	Bailer check clear
	2/20/2025	0.0	Bailer check clear
	2/20/2025	0.0	Bailer check clear
	2/20/2025	0.0	Bailer check clear
	2/20/2025	0.0	Spacer blocked bailer
	2/20/2025	0.0	Bailer check clear
	2/20/2025	0.0	Wellhead that services this property is buried; Old cobblestone well on property was screened (0.0 ppm)
	2/20/2025	-	Wellhead unable to be opened due to seal
	2/20/2025	-	Wellhead unable to be opened due to seal (in basement)
	2/20/2025	0.0	Bailer check clear
	2/20/2025	-	Well is buried
	2/20/2025	-	Well is buried
	2/21/2025	0.0	Bailer check clear
	2/21/2025	0.0	Bailer check clear
	2/21/2025	0.0	Bailer check clear
	2/21/2025	0.0	Bailer check clear
	2/21/2025	0.0	Bailer check clear
	2/21/2025	0.0	Bailer check clear
	2/21/2025	0.0	Bailer check clear
	2/21/2025	0.0	Bailer check clear

Wellhead Screening Summary Table

Address		Date	Wellhead PID Reading (ppm)	Wellhead check observations / Comments
		2/21/2025	0.0	Bailer check clear
		2/21/2025	0.0	Bailer check clear
		2/21/2025	0.0	Bailer check clear
		2/21/2025	-	Unable to locate well
		2/21/2025	0.0	Bailer check clear
		2/21/2025	0.0	Bailer check clear
		2/21/2025	0.0	Bailer check clear
		2/21/2025	0.0	Bailer check clear
		2/21/2025	0.0	Spacer blocked bailer
		2/21/2025	-	Wellhead is inaccessible (in a wall of a closet)
		2/21/2025	-	Well is buried
		2/22/2025	-	Wellhead is inaccessible
		2/22/2025	0.0	Bailer check clear
		2/22/2025	0.0	Bailer check clear
		2/22/2025	0.0	Bailer check clear
		2/22/2025	0.0	Bailer check clear
		2/22/2025	0.0	Bailer check clear
		2/22/2025	0.0	Spacers blocked bailer
		2/22/2025	0.0	Bailer check clear
		2/22/2025	0.0	Bailer check clear
		2/22/2025	0.0	Bailer check clear
		2/22/2025	0.0	Bailer check clear
		2/22/2025	0.0	Bailer got stuck
		2/22/2025	-	Well is buried
		2/22/2025	0.0	Bailer check clear
		2/22/2025	0.0	Bailer check clear
		2/22/2025	-	Well is inaccessible (under deck)
		2/22/2025	-	Unable to open well
		2/22/2025	0.0	Bailer check clear
		2/22/2025	0.0	Spacers blocked bailer
		2/22/2025	0.0	Bailer check clear
		2/24/2025	0.0	Bailer check clear

Wellhead Screening Summary Table

Address	Date	Wellhead PID Reading (ppm)	Wellhead check observations / Comments
	2/24/2025	0.0	Bailer check clear
	2/24/2025	0.0	Bailer check clear
	2/24/2025	0.0	Spacers blocked bailer
	2/24/2025	0.0	Bailer check clear
	2/24/2025	0.0	Bailer check clear
	2/24/2025	59.5	Bailer check clear
	2/24/2025	-	Unable to open wellhead
	2/24/2025	0.0	Spacers blocked bailer
	2/24/2025	0.0	Bailer check clear
	2/24/2025	-	Unable to locate well
	2/24/2025	-	Well is buried
	2/24/2025	0.0	Bailer check clear
	2/24/2025	0.0	Bailer check clear
	2/24/2025	0.0	Spacers blocked bailer
	2/25/2025	0.0	Bailer check clear
	2/25/2025	0.0	Bailer check clear
	2/25/2025	0.0	Bailer check clear
	2/25/2025	0.0	Bailer check not completed due to water in vault where well is located and the seal was unable to be removed
	2/25/2025	0.0	Bailer check clear
	2/25/2025	-	Wellhead inaccessible due to old bolts (unable to open)
	2/25/2025	0.0	Bailer check not completed as additional excavation would be needed to remove piping from wellhead located 30 inches below grade
	2/25/2025	0.0	Bailer check clear
	2/25/2025	0.0	Bailer check clear
	2/25/2025	0.0	Bailer check clear
	2/25/2025	-	Wellhead unable to be opened by sampling crew
	2/25/2025	0.0	Bailer check clear
	2/25/2025	0.0	Bailer check clear
	2/25/2025	0.0	Bailer check clear
	2/25/2025	-	Wellhead is buried

Wellhead Screening Summary Table

Address	Date	Wellhead PID Reading (ppm)	Wellhead check observations / Comments
	2/25/2025	0.0	Bailer check clear
	2/25/2025	0.0	Bailer check clear
	2/26/2025	0.0	Bailer check clear
	2/26/2025	0.0	Bailer check clear
	2/26/2025	-	Could not access wellhead due to bolts on seal
	2/26/2025	-	Bailer stuck in well
	2/26/2025	0.0	Bailer check clear
	2/26/2025	-	Unable to open well
	2/26/2025	0.0	Bailer check clear
	2/26/2025	0.0	Bailer check clear
	2/26/2025	0.0	Bailer check clear
	2/26/2025	0.0	Bailer check clear
	2/26/2025	0.0	Bailer check clear
	2/26/2025	0.0	Bailer check clear
	2/26/2025	0.0	Bailer check clear
	2/26/2025	0.0	Bailer check clear
	2/26/2025	0.0	Bailer check clear
	2/26/2025	-	Unable to open well
	2/26/2025	0.0	Bailer check clear
	2/26/2025	0.0	Bailer check unable to be completed due to spacers in well
	2/26/2025	0.0	Bailer check unable to be completed due to spacers in well
	2/26/2025	0.0	Bailer check clear
	2/26/2025	0.0	Bailer check clear
	2/26/2025	0.0	Bailer check clear
	2/26/2025	0.0	Unable to open well for bailer check
	2/26/2025	0.0	Bailer check clear
	2/27/2025	-	Well can't be accessed due to overgrown tree roots
	2/27/2025	0.0	Bailer check clear
	2/27/2025	0.0	Bailer check clear
	2/27/2025	-	Unable to locate well
	2/27/2025	0.0	Bailer check clear
	2/27/2025	0.0	Bailer check clear
	2/27/2025	0.0	Bailer check clear
	2/27/2025	0.0	Bailer check clear

Wellhead Screening Summary Table

Address	Date	Wellhead PID Reading (ppm)	Wellhead check observations / Comments
	2/27/2025	0.0	Bailer check clear
	2/27/2025	0.0	Bailer check clear
	2/27/2025	0.0	Bailer check clear
	2/27/2025	0.0	Bailer check clear
	2/27/2025	0.0	Bailer check clear
	2/27/2025	0.0	Bailer check clear
	2/27/2025	0.0	Bailer check clear
	2/27/2025	0.0	Bailer stuck on spacers
	2/27/2025	0.0	Bailer check clear
	2/27/2025	0.0	Bailer check clear
	2/27/2025	0.0	Bailer check clear
	2/27/2025	-	Unable to access well due to compression seal
	2/27/2025	0.0	Bailer check clear
	2/27/2025	-	Unable to locate well
	2/27/2025	0.0	Bailer check clear
	2/27/2025	0.0	Bailer check clear
	2/27/2025	0.0	Bailer check clear
	2/27/2025	-	Wells are covered and innaccessible
	2/27/2025	-	Wells are covered and innaccessible
	2/27/2025	0.0	Bailer check clear
	2/28/2025	-	Unable to locate wellhead
	2/28/2025	0.0	Bailer check clear
	2/28/2025	0.1	Bailer check clear
	2/28/2025	0.0	Bailer check clear
	2/28/2025	0.0	Bailer check clear
	2/28/2025	0.0	Bailer blocked by spacer
	2/28/2025	0.0	Bailer check clear
	2/28/2025	0.0	Bailer check clear
	2/28/2025	0.0	Bailer check clear
	2/28/2025	0.0	Bailer check clear
	2/28/2025	0.0	Bailer check clear
	2/28/2025	0.0	Bailer check clear
	2/28/2025	0.0	Bailer check clear

Wellhead Screening Summary Table

Address	Date	Wellhead PID Reading (ppm)	Wellhead check observations / Comments
	2/28/2025	0.0	Bailer check clear
	2/28/2025	0.0	Bailer check clear
	2/28/2025	-	Unable to open wellhead
	2/28/2025	0.0	Bailer check clear
	2/28/2025	0.0	Bailer check clear
	2/28/2025	0.0	Bailer got stuck
	2/28/2025	0.0	Bailer got stuck
	2/28/2025	0.0	Bailer check clear
	2/28/2025	0.0	Bailer check clear
	2/28/2025	-	Well is buried
	2/28/2025	0.0	Bailer got stuck
	3/1/2025	0.0	Bailer check clear
	3/1/2025	0.0	Bailer check clear
	3/1/2025	0.0	Homeowner did not want bailer test
	3/1/2025	0.0	Bailer check clear
	3/1/2025	0.0	Bailer check clear
	3/1/2025	0.0	Bailer check clear
	3/1/2025	0.0	Bailer check clear
	3/1/2025	0.0	Bailer check clear
	3/1/2025	0.0	Bailer check clear
	3/1/2025	0.0	Bailer check clear
	3/1/2025	-	Well is buried under patio pavers
	3/1/2025	0.0	Bailer check clear
	3/1/2025	0.0	Sediment blocking bailer in well
	3/1/2025	0.0	Bailer check clear
	3/1/2025	0.0	Bailer check clear
	3/1/2025	-	Wellhead is in a shed and 6 feet below grade
	3/1/2025	-	Well unable to be accessed, under a large vault
	3/1/2025	0.1	Wellhead is bolted shut, unable to open
	3/1/2025	-	Wellhead is buried
	3/3/2025	0.0	Bailer check clear
	3/3/2025	0.0	Bailer check clear
	3/3/2025	0.0	Bailer check clear

Wellhead Screening Summary Table

Address	Date	Wellhead PID Reading (ppm)	Wellhead check observations / Comments
	3/3/2025	0.0	Bailer check clear
	3/3/2025	0.1	Bailer check clear
	3/3/2025	0.0	Unable to remove lid for bailer check
	3/3/2025	0.0	Could not fit bailer in well
	3/3/2025	-	Unable to locate wellhead
	3/3/2025	0.0	Bailer check clear
	3/3/2025	0.0	Bailer check clear
	3/3/2025	0.0	Bailer check clear
	3/3/2025	0.0	Bailer check clear
	3/4/2025	0.0	Bailer check clear
	3/4/2025	-	Wellhead could not be accessed
	3/4/2025	0.0	Bailer check clear
	3/4/2025	0.0	Bailer check clear
	3/4/2025	0.0	Bailer check not completed at homeowner request
	3/4/2025	0.6, then 0.0	Bailer check clear
	3/4/2025	0.0	Bailer check clear
	3/4/2025	0.0	Bailer check clear
	3/4/2025	0.0	Wellhead could not be opened for bailer check
	3/4/2025	0.0	Bailer check clear
	3/4/2025	0.0	Bailer check clear
	3/4/2025	0.0	Bailer check clear
	3/4/2025	0.0	Bailer check clear
	3/4/2025	0.0	Bailer check clear
	3/5/2025	0.0	Bailer check not completed at homeowner request
	3/5/2025	0.0	Bailer check clear
	3/5/2025	0.0	Bailer check clear
	3/5/2025	-	Unable to remove well lid
	3/5/2025	-	Unable to remove well lid
	3/5/2025	0.0	Bailer check clear
	3/5/2025	-	Well is buried 6 feet underground
	3/5/2025	0.0	Bailer check clear

Wellhead Screening Summary Table

Address	Date	Wellhead PID Reading (ppm)	Wellhead check observations / Comments
	3/5/2025	0.0	Bailer check clear
	3/5/2025	0.0	Bailer check clear
	3/5/2025	0.0	Bailer check clear
	3/5/2025	-	Well inaccessible due to sanitary seal
	3/5/2025	-	Well is buried 4 feet underground
	3/5/2025	0.0	Bailer check clear
	3/5/2025	-	Well is inaccessible due to sheared bolts
	3/5/2025	0.0	Bailer check clear
	3/5/2025	0.0	Well opening is too small for bailer
	3/5/2025	0.0	Could not get bailer past spacer
	3/5/2025	0.0	Bailer check clear
	3/5/2025	0.0	Bailer check incomplete due to spacers and downpipe
	3/5/2025	0.0	Bailer check not completed due to obstruction at 3 feet
	3/6/2025	0.0	Bailer check clear
	3/6/2025	0.0	Unable to remove well lid for bailer check due to equipment on top of well
	3/6/2025	0.0	Bailer check incomplete due to obstruction
	3/6/2025	-	Wellhead check incomplete due to rusted bolts on cap
	3/6/2025	0.0	Bailer check clear
	3/6/2025	0.0	Bailer check clear
	3/6/2025	0.0	Bailer check clear
	3/6/2025	2.0	Bailer check clear
	3/6/2025	-	Wellhead is buried
	3/6/2025	0.0	Bailer check clear
	3/6/2025	0.0	Bailer check clear
	3/6/2025	0.0	Bailer check clear
	3/6/2025	0.0	Bailer check clear
	3/6/2025	0.0	Bailer check clear
	3/7/2025	0.0	Well is in a manhole, unable to conduct bailer check
	3/7/2025	0.0	Bailer encountered obstruction at 50 feet
	3/7/2025	0.0	Bailer check clear

Wellhead Screening Summary Table

Address	Date	Wellhead PID Reading (ppm)	Wellhead check observations / Comments
	3/7/2025	0.0	Bailer check clear
	3/7/2025	0.0	Bailer check clear
	3/7/2025	-	Wellhead is buried
	3/7/2025	0.0	Bailer check clear
	3/7/2025	-	Unable to locate wellhead
	3/7/2025	0.0	Unable to remove lid of vault for bailer test; PID collected from opening
	3/7/2025	0.0	Bailer check clear
	3/7/2025	-	Unable to access wellhead (under brick walkway)
	3/7/2025	0.0	Bailer check clear
	3/7/2025	0.0	Bailer check clear
	3/7/2025	0.0	Bailer check clear
	3/7/2025	0.0	Bailer check clear
	3/7/2025	0.0	Bailer check clear
	3/7/2025	0.0	Bailer check clear
	3/7/2025	0.0	Bailer stuck in well
	3/7/2025	0.0	Unable to open wellhead due to sanitary seal
	3/7/2025	0.0	Bailer check clear
	3/7/2025	0.0	Bailer check clear
	3/7/2025	0.0	Bailer check clear
	3/7/2025	0.0	Wellhead inaccessible due to rusted bolts
	3/7/2025	-	Wellhead inaccessible due to sanitary seal
	3/7/2025	0.0	Bailer check clear
	3/7/2025	0.0	Bailer check clear
	3/8/2025	-	Unable to remove wellhead cap
	3/8/2025	0.0	Bailer check clear
	3/8/2025	0.0	Bailer check clear
	3/8/2025	0.0	Bailer check clear
	3/8/2025	0.0	Bailer check clear
	3/8/2025	0.0	Bailer blocked by spacer
	3/8/2025	0.0	Bailer check clear
	3/8/2025	0.0	Bailer check clear
	3/8/2025	-	Well is inaccessible

Wellhead Screening Summary Table

Address		Date	Wellhead PID Reading (ppm)	Wellhead check observations / Comments
		3/8/2025	0.0	Bailer check clear
		3/8/2025	-	Well is inaccessible; compression wellhead in confined space
		3/8/2025	0.0	Bailer check clear
		3/8/2025	0.0	Bailer check clear
		3/8/2025	0.0	Bailer check clear
		3/10/2025	0.0	Bailer check clear
		3/10/2025	0.0	Bailer check clear
		3/10/2025	0.0	Bailer check clear
		3/10/2025	0.0	Spacer blocked bailer
		3/10/2025	0.0	Bailer check clear
		3/10/2025	0.0	Bailer check clear
		3/10/2025	0.0	Bailer check clear
		3/10/2025	0.0	Bailer check clear
		3/10/2025	0.0	Bailer check clear
		3/10/2025	0.0	Bailer check clear
		3/10/2025	0.0	Bailer check clear
		3/10/2025	-	Unable to access well as it is located in enclosed space
		3/10/2025	0.0	Bailer check clear
		3/10/2025	0.0	Bailer check clear
		3/10/2025	0.0	Bailer check clear
		3/10/2025	0.0	Bailer check clear
		3/10/2025	0.0	Bailer check clear
		3/10/2025	0.0	Bailer check clear
		3/10/2025	0.0	Unable to remove wellhead cap for bailer check
		3/10/2025	-	PID and wellhead check denied by land owner
		3/10/2025	0.0	Bailer check clear
		3/10/2025	0.0	Bailer check clear
		3/10/2025	0.0	Bailer check clear
		3/10/2025	0.0	Bailer check clear
		3/11/2025	0.0	Bailer check clear
		3/11/2025	0.0	Bailer check clear
		3/11/2025	0.0	Bailer check clear

Wellhead Screening Summary Table

Address		Date	Wellhead PID Reading (ppm)	Wellhead check observations / Comments
		3/11/2025	0.0	Bailer check clear
		3/11/2025	0.0	Bailer check clear
		3/11/2025	0.0	Bailer check clear
		3/11/2025	0.0	Bailer check clear
		3/11/2025	0.0	Bailer check clear
		3/11/2025	0.0	Bailer check clear
		3/11/2025	0.0	Bailer check clear
		3/11/2025	0.0	Bailer check clear
		3/11/2025	0.0	Bailer check clear
		3/11/2025	0.0	Bailer check clear
		3/11/2025	0.0	Bailer check clear
		3/11/2025	0.0	Bailer check clear
		3/12/2025	0.0	Bailer check clear
		3/12/2025	0.0	Bailer check clear
		3/12/2025	0.0	Bailer check clear
		3/12/2025	0.0	Bailer check clear
		3/12/2025	0.0	Bailer check clear
		3/12/2025	0.0	Bailer check clear
		3/12/2025	0.0	Bailer check clear
		3/12/2025	0.0	Bailer check clear
		3/12/2025	0.0	Bailer check clear
		3/12/2025	0.0	Bailer check clear
		3/12/2025	0.0	Bailer check clear
		3/13/2025	0.0	Bailer check clear
		3/13/2025	0.0	Unable to do bailer check; wellhead is buried 3 feet below grade; PID screening completed at vent tube
		3/13/2025	0.0	Bailer check clear
		3/13/2025	0.0	Bailer check clear
		3/13/2025	0.0	Bailer check clear
		3/13/2025	0.0	Bailer check clear
		3/13/2025	0.0	Bailer check clear
		3/13/2025	0.0	Bailer check clear
		3/13/2025	0.0	Bailer check clear

Wellhead Screening Summary Table

Address	Date	Wellhead PID Reading (ppm)	Wellhead check observations / Comments
	3/14/2025	0.0	Bailer check clear
	3/14/2025	0.0	Bailer check clear
	3/14/2025	0.0	Bailer check clear
	3/14/2025	0.0	Bailer check clear
	3/14/2025	0.0	Bailer check clear
	3/14/2025	0.0	Bailer check clear
	3/14/2025	0.0	Bailer check clear
	3/14/2025	0.0	Bailer check clear
	3/14/2025	0.0	Bailer check clear
	3/14/2025	0.0	Bailer check clear
	3/15/2025	0.0	Bailer check clear
	3/15/2025	0.0	Bailer check clear (for all 3 wells)
	3/15/2025	-	Not accessed per resident request due to new seal
	3/15/2025	0.0	Bailer check clear
	3/15/2025	0.0	Bailer check clear
	3/15/2025	0.0	Bailer check clear
	3/15/2025	0.0	Bailer check clear
	3/15/2025	0.0	Bailer check clear
	3/15/2025	-	Wellhead could not be opened
	3/15/2025	0.0	Bailer check clear
	3/15/2025	-	Wellhead could not accessed (under concrete)
	3/15/2025	0.0	Bailer check clear
	3/15/2025	0.0	Bailer check clear
	3/15/2025	0.0	Bailer check clear
	3/15/2025	0.0	Bailer check clear
	3/15/2025	0.0	Bailer stuck in well
	3/15/2025	0.0	Bailer check clear
	3/15/2025	0.0	Bailer check clear
	3/17/2025	0.0	Bailer check clear
	3/17/2025	0.0	Bailer check clear
	3/17/2025	0.0	Unable to open well due to grate over well
	3/17/2025	-	Well buried under gravel in driveway

Wellhead Screening Summary Table

Address		Date	Wellhead PID Reading (ppm)	Wellhead check observations / Comments
		3/17/2025	0.0	Bailer check clear
		3/17/2025	0.0	Bailer check clear
		3/17/2025	0.0	Bailer check clear
		3/17/2025	0.0	Bailer check clear
		3/17/2025	0.0	Bailer check clear
		3/17/2025	0.0	PID collected at well vent; wellhead is buried
		3/17/2025	-	Well is inaccessible; located in manhole vault that is sealed
		3/17/2025	0.0	Bailer check clear
		3/17/2025	0.0	Bailer check clear
		3/17/2025	0.0	Bailer check clear
		3/17/2025	0.0	Bailer check clear
		3/17/2025	0.0	Bailer check clear
		3/17/2025	0.0	Bailer check clear
		3/17/2025	0.0	Bailer check clear